DHKK

CHARTERED SURVEYORS

HOME REPORT



31 HOLLYBANK TERRACE
EDINBURGH
EH11 1SP

INSPECTION DATE:

12TH OCTOBER 2026

PREPARED BY:

Fergus Mair, BSc (Hons) MRICS

DHKK Ltd Chartered Surveyors,
Head Office: 54 Corstorphine Road, Edinburgh, EH12 6JQ
Tel: 0131 313 0444, email: edinburgh@dhkk.co.uk
Kinross Office: Kingfisher House, Auld Mart Business Park, Orwell Road, Kinross, KY13 9DA
Tel: 01577 330325, email: kinross@dhkk.co.uk
Company Registration No: SC339964, Vat No: 929947951

1. INFORMATION AND SCOPE OF INSPECTION

This section tells you about the type, accommodation, neighbourhood, age and construction of the property. It also tells you about the extent of the inspection and highlights anything that the surveyor could not inspect.

All references to visual inspection refer to an inspection from within the property without the need to move any obstructions and externally from ground level within the site and adjoining public areas. Any references to left or right are taken facing the front of the property.

The inspection is carried out without causing damage to the building or its contents and without endangering the occupiers or the surveyor. Heavy furniture, stored items and insulation are not moved. Unless identified in the report the surveyor will assume that no harmful or hazardous materials or techniques have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

Services such as TV/cable connection, internet connection, swimming pools and other leisure facilities etc. were not inspected or reported on.

Description
The subjects comprise a lower flatted dwelling in a two storey end terraced block.
Accommodation
Ground Floor; Vestibule, Hall, Living Room, Kitchen with Utility off, Two Bedrooms and Bathroom.
Gross internal floor area (m^2)
Circa 78 m^2.
Neighbourhood and location
The subjects are located within an established residential area within the centre of the city where local facilities and amenities are readily available.
Age
Built circa 1887.
Weather
Clear and dry.
Chimney stacks
Visually inspected with the aid of binoculars where appropriate. Stone and brick render. Our external inspection was carried out from accessible ground levels only and was limited accordingly.

Roofing including roof space
Sloping roofs were visually inspected with the aid of binoculars where appropriate. Flat roofs were visually inspected from vantage points within the property and where safe and reasonable to do so from a 3m ladder externally. Roof spaces were visually inspected and were entered where there was safe and reasonable access, normally defined as being from a 3m ladder within the property. If this is not possible, then physical access to the roof space may be taken by other means if the Surveyor deems it safe and reasonable to do so. Pitched and slated roof. Our external inspection was carried out from accessible ground levels only to the front of the building and was limited accordingly. No inspection of any roof space.
Rainwater fittings
Visually inspected with the aid of binoculars where appropriate. Cast iron gutters with downpipes discharging into a drainage system.
Main walls
Visually inspected with the aid of binoculars where appropriate. Foundations and concealed parts were not exposed or inspected. Main walls are of solid stone construction.
Windows, external doors and joinery
Internal and external doors were opened and closed where keys were available. Random windows were opened and closed where possible. Doors and windows were not forced open. Aluminium double glazed with more modern timber frame double glazing at the utility room. Some working shutters.
External decorations
Visually inspected.
Conservatories / porches
Not applicable.
Communal areas
Not applicable.
Garages and permanent outbuildings
Not applicable.

Outside areas and boundaries
Visually inspected. Private ground to front and rear.
Ceilings
Visually inspected from floor level. Ceilings appear of lath and plaster and plasterboard construction.
Internal walls
Visually inspected from floor level. Using a moisture meter, walls were randomly tested for dampness where considered appropriate. Walls appear of plaster on the hard, lath and plaster and plasterboard construction.
Floors including sub floors
Surfaces of exposed floors were visually inspected. No carpets or floor coverings were lifted. Sub-floor areas were inspected only to the extent visible from a readily accessible and unfixed hatch by way of an inverted "head and shoulders" inspection at the access point. Physical access to the sub floor area may be taken if the Surveyor deems it is safe and reasonable to do so, and subject to a minimum clearance of 1m between the underside of floor joists and the solum as determined from the access hatch. Suspended and solid flooring. Floors partially covered. No inspection of any sub floor area.
Internal joinery and kitchen fittings
Built-in cupboards were looked into but no stored items were moved. Kitchen units were visually inspected excluding appliances. Floor and wall mounted kitchen units. Skirting, architraves and doors.
Chimney breasts and fireplaces
Visually inspected. No testing of the flues or fittings was carried out. Open gas fire.
Internal decorations
Visually inspected.
Cellars
Not applicable.

Electricity
Accessible parts of the wiring were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on. The electrical system appears along mixed lines with there being a consumer unit within the vestibule in addition to older style faceplates to sockets and switches.
Gas
Accessible parts of the system were visually inspected without removing fittings. No tests whatsoever were carried out to the system or appliances. Visual inspection does not assess any services to make sure they work properly and efficiently and meet modern standards. If any services are turned off, the surveyor will state that in the report and will not turn them on. Mains. The meter is located within the front garden attached to a boundary wall.
Water, plumbing and bathroom fittings
Visual inspection of the accessible pipework, water tanks, cylinders and fittings without removing any insulation. No tests whatsoever were carried out to the system or appliances. Plumbing and fittings appear of copper/PVC piping, where seen. Three piece bathroom suite. There is a drained cold water tank above the bathroom. We assume all original lead plumbing has been modernised.
Heating and hot water
Accessible parts of the system were visually inspected apart from communal systems, which were not inspected. No tests whatsoever were carried out to the system or appliances. Heating and hot water is by way of a gas fired condensing boiler located within the utility room.
Drainage
Drainage covers etc were not lifted. Neither drains nor drainage systems were tested. Mains.
Fire, smoke and burglar alarms
Visually inspected. No tests whatsoever were carried out to the system or appliances. Fire detection and alarm equipment are present within the property. We recommend that it be verified that the provision meets with current fire safety standards.

Any additional limits to inspection:

Only the subject flat and internal communal areas giving access to the flat were inspected.

If the roof space or under-building / basement is communal, reasonable and safe access is not always possible. If no inspection was possible, this will be stated. If no inspection was possible, the surveyor will assume that there are no defects that will have a material effect on the valuation.

The building containing the flat, including any external communal areas, was visually inspected only to the extent that the surveyor is able to give an opinion on the general condition and standard of maintenance.

We did not inspect the property for the purpose of identifying invasive plants. Invasive plant species are ones which typically cause ecological or economic harm in a new environment where they are not native. In some instances, invasive plants can also cause damage to built structures and may render property unsuitable for mortgage lending. While not an exhaustive list, invasive plant species include Japanese Knotweed, Giant Hogweed and Himalayan Balsam. Our valuation is made on the basis that invasive plant species are not present and note that identification is best carried out by a specialist contractor. Commonly invasive plant species require eradication by licensed contractors and the cost of eradication works may prove significant. Where we are made aware of invasive plant species being present at a property, we reserve the right to revise our assessment of Market Value.


The valuation assumes that no deleterious nor hazardous materials nor techniques have been used in the construction, and that the land is not contaminated.

A structural survey was not instructed and we have not inspected the woodwork or other parts of the property which are covered, unexposed or inaccessible and we are therefore unable to report that any such part of the property is free from defect.

It is outwith the scope of this inspection to determine whether or not asbestos based products are present within the property. Asbestos was widely used in the building industry until around 1999, when it became a banned substance. If you have any concerns you should engage the services of a qualified asbestos surveyor.

The dwelling was unfurnished and unoccupied but holding some stored items. Our external inspection was carried out from accessible ground levels only and was limited accordingly.

Sectional diagram showing elements of a typical house



Reference may be made in this report to some or all of the above building elements of the property.

This diagram may assist you in locating and understanding these terms.

2. CONDITION

This section identifies problems and tells you about the urgency of any repairs by using one of three categories.

Repair Categories

Category 1:
No immediate action or repair

Category 2:
Repairs or replacement requiring future attention, but estimates are still advised.

Category 3:
Urgent Repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.

 **Structural movement**	
Repair category	1
Notes:	There is evidence of previous structural movement in the building noted both internally and externally but this is not inconsistent with a property of this age and type and on the basis of a single inspection appears to be longstanding.
 **Dampness, rot and infestation**	
Repair category	2
Notes:	Some isolated damp readings were noted. It is recommended that a reputable timber/damp specialist firm be employed to carry out a detailed inspection of the entire subjects and thereafter implement all necessary remedial works under cover of long term guarantee. Subsequent to our inspection, we have had sight of a report from Valentines Property Services dated 20th October 2026 and any potential purchaser should satisfy themselves with its content.
 **Chimney stacks**	
Repair category:	2
Notes:	Damaged render. It would be prudent to have the chimney stacks inspected at the time of the roof inspection.

 **Roofing including roof space**	
Repair category:	2
Notes:	The roof covering is now of an age where ongoing and regular maintenance will be required and the advice of a roofing contractor to comment on its current condition and expected lifespan should be sought. We have been informed that there are some roof repairs to be carried out imminently and details of this should be sought.
 **Rainwater fittings**	
Repair category:	1
Notes:	At the time of our inspection there was no evidence of damp staining/water staining on wall surfaces which would indicate leakage. It should be noted that it was not raining at the time of our inspection.
 **Main walls**	
Repair category:	2
Notes:	Some weathered stonework.
 **Windows, external doors and joinery**	
Repair category:	1
Notes:	Some windows are of some age. A precautionary check of all windows and doors should be carried out prior to purchase. Windows can be problematic and over time the operation of the windows can be affected and opening mechanisms damaged. It is therefore likely that maintenance/ repair will be required as part of an ongoing maintenance programme. Double glazed windows may be prone to misting/interstitial condensation which can be more evident and can change in certain temperatures/weather conditions.
 **External decorations**	
Repair category:	1
Notes:	The external decorations are generally in fair order. Regular repainting will be required if these areas are to be maintained in satisfactory condition.

 **Conservatories / porches**	
Repair category:	Not applicable.
Notes:	Not applicable.
 **Communal areas**	
Repair category:	Not applicable.
Notes:	Not applicable.
 **Garages and permanent outbuildings**	
Repair category:	Not applicable.
Notes:	Not applicable.
 **Outside areas and boundaries**	
Repair category:	2
Notes:	Some movement noted to a boundary wall in addition to defective pointing. The extent of the boundaries should be confirmed by your solicitor.
 **Ceilings**	
Repair category:	1
Notes:	Cracking and blemishes have occurred and some plaster repairs may be required (during redecoration).
 **Internal walls**	
Repair category:	1
Notes:	Within the limits of our inspection these generally appeared in a condition consistent with age. During redecoration some plaster filling/repair may be required.

 **Floors including sub-floors**	
Repair category:	1
Notes:	No access to the sub-floor chamber was possible at the time of our visit to the property. Within the limitations of our inspection there was no indication to suggest significant defects in this area. It will, however be appreciated that the area was not inspected and therefore no guarantees can be provided in this regard.
 **Internal joinery and kitchen fittings**	
Repair category:	1
Notes:	The internal joinery is generally in keeping with the age and type of property and is in a condition consistent with age. The kitchen fittings are generally in adequate condition for their age and type although worn in parts. A door has been removed from a kitchen. Ensure glass to the vestibule door is of an adequate safety type.
 **Chimney breasts and fireplaces**	
Repair category:	1
Notes:	There is a fireplace installed within the property incorporating an open gas fire. It should be emphasised that the flues was not checked or the appliance tested.
 **Internal decorations**	
Repair category:	2
Notes:	Worn decoration.
 **Cellars**	
Repair category:	Not applicable.
Notes:	Not applicable.

Electricity	
Repair category:	2
Notes:	The electrical system is on mixed lines and as such we recommend that it be checked and upgraded as necessary by an NICEIC/SELECT registered Electrical Contractor.
Gas	
Repair category:	1
Notes:	In the interest of safety all gas appliances should be checked by a Gas Safe Registered Engineer.
Water, plumbing and bathroom fittings	
Repair category:	1
Notes:	The plumbing where seen is of copper supply pipes and uPVC waste pipes. It should be noted that within a property of this age the original plumbing installation would have been in lead and it is possible that sections of concealed lead pipework will be found to remain. It should be appreciated that concealed areas beneath and around baths and shower trays could not be inspected. Water spillage in these areas can result in dampness/decay and no comment can be made on inaccessible areas. Waterproof seals in sanitary areas should be checked and maintained on a regular basis. The sanitary fittings appeared in fair order consistent with age.
Heating and hot water	
Repair category:	1
Notes:	There is a gas fired central heating system and gas fittings and these should all be checked and serviced in the normal manner. In the interests of safety it would be prudent to have all gas appliances checked by a Gas Safe registered tradesman.
Drainage	
Repair category:	1
Notes:	The property is thought to be connected to a main sewer. There was no surface evidence to suggest the system is choked or leaking.

Set out below is a summary of the condition of the property which is provided for reference only. You should refer to the comments above for detailed information.

Structural movement	1
Dampness, rot and infestation	2
Chimney stacks	2
Roofing including roof space	2
Rainwater fittings	1
Main walls	2
Windows, external doors and joinery	1
External decorations	1
Conservatories / porches	Not applicable
Communal areas	Not applicable
Garages and permanent outbuildings	Not applicable
Outside areas and boundaries	2
Ceilings	1
Internal walls	1
Floors including sub-floors	1
Internal joinery and kitchen fittings	1
Chimney breasts and fireplaces	1
Internal decorations	2
Cellars	Not applicable
Electricity	2
Gas	1
Water, plumbing and bathroom fittings	1
Heating and hot water	1
Drainage	1

Repair Categories

Category 3:
Urgent Repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.

Category 2:
Repairs or replacement requiring future attention, but estimates are still advised.

Category 1:
No immediate action or repair is needed.

Remember

The cost of repairs may influence the amount someone is prepared to pay for the property. We recommend that relevant estimates and reports are obtained in your own name.

Warning

If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions where the effect can be considerable.

3. ACCESSIBILITY INFORMATION

Guidance Notes on Accessibility Information

Three steps or fewer to a main entrance door of the property: In flatted developments the 'main entrance' would be the flat's own entrance door, not the external door to the communal stair. The 'three steps or fewer' are counted from external ground level to the flat's entrance door. Where a lift is present, the count is based on the number of steps climbed when using the lift.

Unrestricted parking within 25 metres: For this purpose, 'Unrestricted parking' includes parking available by means of a parking permit. Restricted parking includes: Parking that is subject to parking restrictions, as indicated by the presence of solid yellow, red or white lines at the edge of the road or by a parking control sign, parking meters or other coin-operated machines.

1.	Which floor(s) is the living accommodation on?	Ground
2.	Are there three steps or fewer to a main entrance door of the property?	Yes
3.	Is there a lift to the main entrance door of the property?	No
4.	Are all door openings greater than 750mm?	No
5.	Is there a toilet on the same level as the living room and kitchen?	Yes
6.	Is there a toilet on the same level as a bedroom?	Yes
7.	Are all rooms on the same level with no internal steps or stairs?	Yes
8.	Is there unrestricted parking within 25 metres of an entrance door to the building?	Yes

4. VALUATION AND CONVEYANCER ISSUES

This section highlights information that should be checked with a solicitor or licensed conveyancer. It also gives an opinion of market value and an estimated re-instatement cost for insurance purposes.

Matters for a solicitor or licensed conveyancer

It is recommended that where repairs, defects or maintenance items have been identified, particularly categorised as a 2 or 3, interested parties make appropriate enquiries in order to satisfy themselves of potential costs and the extent of the works required prior to submitting a legal offer to purchase.

We are unaware of any adverse planning proposals affecting the subjects although this should be confirmed by obtaining a Property Enquiry Certificate.

We assume that the carriageways etc., ex adverso the subjects are the responsibility of the Local Authority.

Absolute Ownership assumed. We are unaware of any easements, servitudes or rights of way which may adversely affect the property. This point should be confirmed by reference to the Title Deeds.

The subjects form part of a block of flats and it has been assumed that maintenance/repair costs of the common parts of the building and external grounds will be shared on an equitable basis with the adjoining proprietors. It is therefore assumed that the costs of repairs detailed within this report which relate to these areas should be apportioned accordingly, although exact liability should be confirmed.

The valuation is made on the assumption that any alterations that may have been carried out to the property satisfy all relevant legislation and have full certification where appropriate. Alterations noted at the time of our inspection appears to include the subdivision of a former double lateral flatted dwelling.

Estimated re-instatement cost for insurance purposes

We recommend that for reinstatement cost assessment purposes, the subjects be insured for a sum not less than £370,000 (THREE HUNDRED AND SEVENTY THOUSAND POUNDS). This figure is an opinion of an appropriate sum for which the property and substantial outbuildings should be insured against total destruction. The figure assumes reconstruction of the property in its existing configuration and in the same materials. The figure bears no direct relationship to current market value. It is recommended that the level of cover is kept under regular review to ensure that you remain adequately insured. For properties with construction types not covered by BCIS, or where properties are Listed or situated within Conservation Areas, you should seek further specialist insurance advice.

Valuation and market comments

It is our opinion the current Market Value of the property on a basis of vacant possession and in current condition may be fairly stated at the sum of £320,000 (THREE HUNDRED AND TWENTY THOUSAND POUNDS).

The Market Value expressed herein is effective as at the date of valuation. The Seller and Buyer are advised that Market Value may rise or fall as market conditions change. Should parties relying on this report and valuation consider market conditions to have changed materially from those prevalent at the date of this valuation, a revaluation should be instructed.

Report author:	Fergus Mair, BSc (Hons) MRICS Ref: 27011/FM/NKD
Address:	DHKK Limited 54 Corstorphine Road, Edinburgh EH12 6JQ
Signed:	
Date of report:	20th October 2026

DHKK
CHARTERED SURVEYORS

PART 1 – GENERAL

1.1 THE SURVEYORS

The seller has engaged the surveyors to provide the Single Survey Report and a generic Mortgage Valuation Report for lending purposes. The seller has also engaged the surveyors to provide an energy report in the format prescribed by the accredited energy assessment company.

The surveyors are authorised to provide a transcript or retype of the generic Mortgage Valuation Report on a lender specific pro-forma. Transcript reports are commonly requested by brokers and lenders. The transcript report will be in the format required by the lender but will contain the same information, inspection date and valuation figure as the generic Mortgage Valuation Report and the Single Survey. The surveyors will decline any transcript request which requires the provision of information additional to the information in the Single Survey Report and the generic Mortgage Valuation Report until the seller has conditionally accepted an offer to purchase made in writing.

Once the seller has conditionally accepted an offer to purchase made in writing the purchaser's lender or conveyancer may request that the surveyors provide general comment on standard appropriate supplementary documentation. In the event of a significant amount of documentation being provided to the surveyors, an additional fee may be incurred by the purchaser. Any additional fee will be agreed in writing.

If information is provided to the surveyors during the conveyancing process which materially affects the valuation stated in the Single Survey Report and generic Mortgage Valuation Report, the surveyors reserve the right to reconsider the valuation. Where the surveyors require to amend the valuation in consequence of such information, they will issue an amended Single Survey Report and generic Mortgage Valuation Report to the seller. It is the responsibility of the seller to ensure that the amended Single Survey Report and generic Mortgage Valuation Report are transmitted to every prospective purchaser.

The individual surveyor will be a member or fellow of the Royal Institution of Chartered Surveyors who is competent to survey, value and report upon residential property.[1]

If the surveyors have had a previous business relationship within the past two years with the seller or seller's agent or relative to the property, they will be obliged to indicate this by ticking the adjacent box. [√]

The surveyors have a written complaints handling procedure. This is available from the offices of the surveyors at the address stated.

1.2 THE REPORT

The surveyors will not provide an amended Single Survey Report on the Property, except to correct factual inaccuracies.

The Single Survey Report will identify the nature and source of information relied upon in its preparation.

[1] Which shall be in accordance with the current RICS Valuation Standards ("The Red Book") and RICS Codes of Conduct.

The surveyor shall provide a Market Value of the property, unless the condition of the property is such that it would be inappropriate to do so. A final decision on whether a loan will be granted rests with the lender who may impose retentions in line with their lending criteria. The date of condition and value of the property will be the date of inspection.

Prior to 1 December 2008, purchasers normally obtained their own report from their chosen surveyor. By contrast, a Single Survey is instructed by the seller and made available to all potential purchasers in the expectation that the successful purchaser will have relied upon it. The Royal Institution of Chartered Surveyors' rules require disclosure of any potential conflict of interest when acting for the seller and the purchaser in the same transaction. The Single Survey may give rise to a conflict of interest and if this is of concern to any party, they are advised to seek their own independent advice.

The report and any expressions or assessments in it are not intended as advice to the seller or purchaser or any other person in relation to an asking price or any other sales or marketing decisions.

The report is based solely on the property and is not to be relied upon in any manner whatsoever when considering the valuation or condition of any other property.

If certain minor matters are mentioned in the report, it should not be assumed that the property is free of other minor defects.

Neither the whole nor any part of the report may be published in any way, reproduced, or distributed by any party other than the seller, prospective purchasers and the purchaser and their respective professional advisers without the prior written consent of the surveyors.

1.3 LIABILITY

The report is prepared with the skill and care reasonably to be expected of a competent residential surveyor who is a member of the Royal Institution of Chartered Surveyors.

The report is addressed to the seller and was prepared in the expectation that it (or a complete copy) along with these Terms and Conditions (or a complete copy) would (or, as the case might be, would have been) be disclosed and delivered to

- the seller;
- any person(s) noting an interest in purchasing the property from the seller;
- any person(s) who make(s) (or on whose behalf is made) an offer to purchase the property, whether or not that offer is accepted by the seller;
- the purchaser; and
- the professional advisers of any of these.

The surveyors acknowledge that their duty of skill and care in relation to the report is owed to the seller and to the purchaser. The surveyors accept no responsibility or liability whatsoever in relation to the report to persons other than the seller and the purchaser. The seller and the purchaser should be aware that if a lender seeks to rely on this report they do so at their own risk. In particular, the surveyors accept no responsibility or liability whatsoever to any lender in relation to the report. Any such lender relies upon the report entirely at their own risk.

1.4 GENERIC MORTGAGE VALUATION REPORT

The surveyors undertake to the seller that they will prepare a generic Mortgage Valuation Report which will be issued along with the Single Survey. It is the responsibility of the seller to ensure that the generic Mortgage Valuation Report is provided to every potential purchaser.

1.5 TRANSCRIPT MORTGAGE VALUATION FOR LENDING PURPOSES

The surveyors undertake that on being asked to do so by a prospective purchaser, or his/her professional adviser or lender, they will prepare a transcript Mortgage Valuation Report for lending purposes on terms and conditions to be agreed between the surveyors and lender and solely for the use of the lender and upon which the lender may rely. The decision as to whether finance will be provided is entirely a matter for the lender. The transcript Mortgage Valuation Report[2] will be prepared from information contained in the report and the generic Mortgage Valuation Report.

1.6 INTELLECTUAL PROPERTY

All intellectual property rights whatsoever (including copyright) in and to the Single Survey Report, excluding the headings and rubrics, are the exclusive property of the surveyors and shall remain their exclusive property unless they assign the same to any other party in writing.

1.7 PAYMENT

The surveyors are entitled to refrain from delivering the report to anyone until the fee and other charges for it notified to the seller have been paid. Additional fees will be charged for subsequent inspections and reports.

1.8 CANCELLATION

The seller will be entitled to cancel the inspection by notifying the surveyor's office at any time before the day of the inspection.

[2] Which shall be in accordance with the current RICS Valuation Standards ("The Red Book") and RICS Rules of Conduct

The surveyor will be entitled not to proceed with the inspection (and will so report promptly to the seller) if after arriving at the property, the surveyor concludes that it is of a type of construction of which the surveyor has insufficient specialist knowledge to be able to provide the inspection satisfactorily. The surveyor will also be entitled not to proceed if after arriving at the property, the surveyor concludes that the property is exempt under Part 3 of The Housing (Scotland) Act 2006 as detailed in the (Prescribed Documents) Regulations 2008. If there is a potential threat to their health or personal safety, the inspection may be postponed or cancelled, at the surveyor's discretion.

In the case of cancellation or the inspection not proceeding, the surveyor will refund any fees paid by the seller for the inspection and report, except for expenses reasonably incurred and any fee due in the light of the final paragraph of this section.

In the case of cancellation by the seller, for whatever reason, after the inspection has taken place but before a written report is issued, the surveyor will be entitled to raise an invoice equivalent to 80% of the agreed fee.

1.9 PRECEDENCE

If there is any incompatibility between these Terms and Conditions and the report, these Terms and Conditions take precedence.

1.10 DEFINITIONS

- the "lender" is the party who has provided or intends or proposes to provide financial assistance to the purchaser towards the purchase of the property and in whose favour a standard security will be granted over the property;
- the "transcript Mortgage Valuation Report for lending purposes" means a separate report, prepared by the surveyor, prepared from information in the report and the generic Mortgage Valuation Report, but in a style and format required by the lender. The transcript Mortgage Valuation Report for lending purposes will be prepared with the skill and care reasonably to be expected from a surveyor who is a member of the Royal Institution of Chartered Surveyors and who is competent to survey, value and report on the property;
- the "generic Mortgage Valuation Report" means a separate report, prepared by the surveyor from information in the report but in the surveyor's own format;
- the "Market Value" is the estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion;
- the "property" is the property which forms the subject of the report;
- the "purchaser" is the person (or persons) who enters into a contract to buy the property from the seller;
- a "prospective purchaser" is anyone considering buying the property;

- the “report” is the report, of the kind described in Part 2 of these Terms and Conditions and in the form set out in Part 1 of Schedule 1 of the Housing (Scotland) Act 2006 (Prescribed Documents) Regulations 2008;
- the “seller” is/are the proprietor(s) of the property;
- the “surveyor” is the author of the report on the property; and
- the “surveyors” are the firm or company of which the surveyor is an employee, director, member or partner (unless the surveyor is not an employee, director, member or partner, when the surveyors means the surveyor) whose details are set out at the head of the report.
- The “energy report” is the advice given by the accredited energy assessment company, based on information collected by the surveyor during the inspection, and also includes an Energy Performance Certificate, in a Government approved format.

PART 2 – DESCRIPTION OF THE REPORT

2.1 THE SERVICE

The Single Survey is a report by an independent surveyor, prepared in an objective way regarding the condition and value of the property on the day of the inspection, and who is a member of the Royal Institution of Chartered Surveyors. It includes an energy report as required by statute and this is in the format of the accredited energy company. In addition, the surveyor has agreed to supply a generic mortgage valuation report.

2.2 THE INSPECTION

The inspection is a general surface examination of those parts of the property which are accessible: in other words, *visible and readily available for examination from ground and floor levels, without risk of causing damage to the property or injury to the surveyor*.

All references to visual inspection refer to an inspection from within the property at floor level and from ground level within the site and adjoining public areas, without the need to move any obstructions. Any references to left or right are taken facing the front of the property.

The inspection is carried out with the seller’s permission, without causing damage to the building or contents. Furniture, stored items and insulation are not moved.

Unless identified in the report the surveyor will assume that no harmful or hazardous materials have been used in the construction. The presence or possible consequences of any site contamination will not be researched.

The surveyor will not carry out an asbestos inspection and will not be acting as an asbestos inspector in completing a Single Survey of properties that may fall within the Control of Asbestos in the Workplace Regulations. In the case of flats, it will be assumed that there is a duty holder, as defined in the Regulations and that a register of asbestos and effective management plan are in place, which does not require any expenditure, or pose a significant risk to health. No enquiry of the duty holder will be made.

2.3 THE REPORT

The report will be prepared by the surveyor who carried out the property inspection and will describe various aspects of the property as defined by the headings of the Single Survey report with the comments being general and unbiased. The report on the location, style and condition of the property, will be concise and will be restricted to matters that could have a material effect upon value and will omit items that, in the surveyor's opinion, are not significant. If certain minor matters are mentioned, it should not be interpreted that the property is free of any other minor defects.

Throughout the report, the following repair categories will be used to give an overall opinion of the state of repair and condition of the property.

1. **Category 3:** Urgent repairs or replacement are needed now. Failure to deal with them may cause problems to other parts of the property or cause a safety hazard. Estimates for repairs or replacement are needed now.
2. **Category 2:** Repairs or replacement requiring future attention, but estimates are still advised.
3. **Category 1:** No immediate action or repair is needed.

WARNING: If left unattended, even for a relatively short period, Category 2 repairs can rapidly develop into more serious Category 3 repairs. The existence of Category 2 or Category 3 repairs may have an adverse effect on marketability, value and the sale price ultimately achieved for the property. This is particularly true during slow market conditions when the effect can be considerable.

Parts of the property, which cannot be seen or accessed, will not be reported upon and this will be stated. If the surveyor suspects that a defect may exist within an unexposed area and which could have a material effect upon the value, he may recommend further investigation by specialist contractors.

2.4 SERVICES

Surveyors are not equipped or qualified to test the services and therefore no comment can be interpreted as implying that the design, installation and function of the services are in accordance/compliance with regulations, safety and efficiency expectations. However, comment is made where there is cause to suspect significant defects or shortcomings with the installations. No tests are made of any services or appliances.

2.5 ACCESSIBILITY

A section is included to help identify the basic information interested parties need to know to decide whether to view a property.

2.6 ENERGY REPORT

A section is included that makes provision for an energy report, relative to the property. The surveyor will collect physical data from the property and provide such data in a format required by an accredited energy company.

The surveyor cannot of course accept liability for any advice given by the energy company.

2.7 VALUATION AND CONVEYANCER ISSUES

The last section of the report contains matters considered relevant to the conveyancer (solicitor). It also contains the surveyor's opinion both of the market value of the property and of the re-instatement cost, as defined below.

"Market Value" is *the estimated amount for which a property should exchange on the date of valuation between a willing buyer and a willing seller in an arm's-length transaction after proper marketing wherein the parties had each acted knowledgeably, prudently and without compulsion.* In arriving at the opinion of the Market Value the surveyor also makes various standard assumptions covering, for example, vacant possession; tenure and other legal considerations; contamination and hazardous materials; the condition of un-inspected parts; the right to use mains services; and the exclusion of curtains, carpets etc. from the valuation. In the case of flats, the following further assumptions are made that:

- *There are rights of access and exit over all communal roadways, corridors, stairways etc. and to use communal grounds, parking areas and other facilities;
- *There are no particularly troublesome or unusual legal restrictions;
- *There is no current dispute between the occupiers of the flats or any outstanding claims or losses; and the costs of repairs to the building are shared among the co-proprietors on an equitable basis.

Any additional assumption, or any found not to apply, is reported.

"Re-instatement cost" *is an estimate for insurance purposes of the current cost of rebuilding the property in its present form* unless otherwise stated. This includes the cost of rebuilding the garage and permanent outbuildings, site clearance and professional fees, but excludes VAT (except on the fees).

Sellers or prospective purchasers should note that the Single Survey is valid for 12 weeks from the date of inspection. Sellers or prospective purchasers may consider it prudent to instruct a reinspection and revaluation after a period of 12 weeks (or sooner if appropriate) to reflect changing circumstances in the market and/or in the physical condition of the property.

DHKK

CHARTERED SURVEYORS

MORTGAGE VALUATION REPORT



DHKK
CHARTERED SURVEYORS

MORTGAGE VALUATION REPORT

Property Address 31 Hollybank terrace, Edinburgh, EH11 1SP **Ref No** 27011/FM/NKD
Date of Inspection 12th October 2026

Property Details

Property Type:

House ☐
Bungalow ☐
Flat ☒
Maisonette ☐
Other:

Property Style:

Detached ☐
Semi Detached ☐
Mid Terrace ☐
End Terrace ☐

If Flat/Maisonette:

Purpose-Built ☒
Converted ☐

Lift in Block

Yes ☐
No ☒

Floor of Subject Property: G

No of Flats in block: 2

No of Floors in Block: 2

Commercial in Block:

Yes ☐
No ☒

Type of Construction (*Specify under general remarks):

Traditional ☒ *Non-Traditional ☐

Property built for the Public Sector:

Yes ☐ No ☒

Tenure

Absolute Owner ☒ Leasehold ☐ **Age of Property:** 139 Years Approximately

Accommodation (specify number of rooms)

Living Rooms	1	Bedrooms	2	Kitchens	1
Bathrooms	1	WCs	0		
Other:	0				

Gross Floor Area (excluding garages & outbuildings) Internal 78 m² External 90 m²

Garage(s) / Outbuildings: No **Parking Space(s):** No

Garden:
Yes ☒
No ☐
Communal ☐

Residential Element – greater than 40%:
Yes ☒
No ☐

Construction

Walls: Brick ☐ Stone ☒ Concrete ☐ Timber-framed ☐
Other:

Roof: Tile ☐ Slate ☒ Asphalt ☐ Felt ☐
Other:

DHKK
CHARTERED SURVEYORS

Structural Movement, Subsidence, Settlement and Landslip

Does the property show signs of, or is the property located near any area subject to structural movement, landslip, heave, settlement, subsidence, flooding, mining?

Yes ☒ No ☐

If yes, please comment:

There is evidence of previous structural movement in the building noted both internally and externally but this is not inconsistent with a property of this age and type and on the basis of a single inspection appears to be longstanding.

Services (Based on visual inspection only. If any services appear to be non-mains, please comment on the type and location of the supply in general remarks)

Drainage:	Mains	☒	Private	☐	None	☐
Water:	Mains	☒	Private	☐	None	☐
Gas:	Mains	☒	Private	☐	None	☐
Electricity:	Mains	☒	Private	☐	None	☐

Solar Panels: Yes ☐ No ☒ **If yes:** Owned ☐ Leased ☐

Central Heating: Yes ☒ Partial ☐ None ☐

Brief description: Full gas.

Location

Residential Suburb	☐	Residential within town/city	☒	Mixed residential/commercial	☐
Mainly Commercial	☐	Commuter Village	☐	Remote Village	☐
Isolated Rural Property	☐	Other*	☐	*Specify in general remarks	

Roads

Made up	☒	Unmade Road	☐	Partly completed new road	☐
Adopted	☒	Unadopted	☐	Pedestrian Access Only	☐

Planning Issues

Has the property been extended / converted / altered

Yes ☒ No ☐

If yes, please comment:

The valuation is made on the assumption that any alterations that may have been carried out to the property satisfy all relevant legislation and have full certification where appropriate. Alterations noted at the time of our inspection appears to include the subdivision of a former double lateral flatted dwelling.

DHKK
CHARTERED SURVEYORS

General Remarks

The dwelling requires both repair and modernisation.

Essential Repairs

None.

Estimated cost of essential repairs £ Retention recommended Yes ☐ No ☐ Amount £

Comment on Mortgageability

The property forms suitable security for mortgage purposes subject to the specific lending criteria of any given mortgage provider.

Valuations (Assuming Vacant Possession)

Market value in present condition	£320,000
Market value on completion of essential repairs	£
Insurance Reinstatement value	£370,000

(to include the cost of total rebuilding, site clearance, professional fees, ancillary charges plus VAT)

Is a Reinspection necessary Yes ☐ No ☒

Signed

Valuers Name and Qualifications	Fergus Mair, BSc (Hons) MRICS
Date of Report	20th October 2026
Company Name	DHKK Ltd
Address	54 Corstorphine Road Edinburgh EH12 6JQ
Tel No	0131 313 0444

DHKK

CHARTERED SURVEYORS

ENERGY PERFORMANCE CERTIFICATE



Energy Performance Certificate (EPC)

Dwellings

Scotland

31 HOLLYBANK TERRACE, POLWARTH, EDINBURGH, EH11 1SP


Dwelling type:	Ground-floor flat	**Reference number:**	9112-2392-1603-2696-6821
Date of assessment:	12 October 2026	**Type of assessment:**	RdSAP, existing dwelling
Date of certificate:	14 October 2026	**Approved Organisation:**	Elmhurst
Total floor area:	78 m²	**Main heating and fuel:**	Boiler and radiators, mains gas
Primary Energy Indicator:	268 kWh/m²/year		

You can use this document to:

- **Compare current ratings of properties to see which are more energy efficient and environmentally friendly**
- **Find out how to save energy and money and also reduce CO_2 emissions by improving your home**

Estimated energy costs for your home for 3 years*	**£4,044**	See your recommendations report for more information
Over 3 years you could save*	**£1,194**	

* based upon the cost of energy for heating, hot water, lighting and ventilation, calculated using standard assumptions




Energy Efficiency Rating

This graph shows the current efficiency of your home, taking into account both energy efficiency and fuel costs. The higher this rating, the lower your fuel bills are likely to be.

Your current rating is **band D (64)**. The average rating for EPCs in Scotland is **band D (61).**

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.



Environmental Impact (CO_2) Rating

This graph shows the effect of your home on the environment in terms of carbon dioxide (CO_2) emissions. The higher the rating, the less impact it has on the environment.

Your current rating is **band D (60)**

The potential rating shows the effect of undertaking all of the improvement measures listed within your recommendations report.

Top actions you can take to save money and make your home more efficient

Recommended measures	Indicative cost	Typical savings over 3 years
1 Internal wall insulation	£7,500 - £11,000	£828.00
2 Floor insulation (suspended floor)	£5,000 - £10,000	£363.00

A full list of recommended improvement measures for your home, together with more information on potential cost and savings and advice to help you carry out improvements can be found in your recommendations report.

To find out more about the recommended measures and other actions you could take today to stop wasting energy and money, visit greenerscotland.org or contact Home Energy Scotland on 0808 808 2282.

THIS PAGE IS THE ENERGY PERFORMANCE CERTIFICATE WHICH MUST BE AFFIXED TO THE DWELLING AND NOT BE REMOVED UNLESS IT IS REPLACED WITH AN UPDATED CERTIFICATE

Summary of the energy performance related features of this home

This table sets out the results of the survey which lists the current energy-related features of this home. Each element is assessed by the national calculation methodology; 1 star = very poor (least efficient), 2 stars = poor, 3 stars = average, 4 stars = good and 5 stars = very good (most efficient). The assessment does not take into consideration the condition of an element and how well it is working. 'Assumed' means that the insulation could not be inspected and an assumption has been made in the methodology, based on age and type of construction.

Element	Description	Energy Efficiency	Environmental
Walls	Sandstone, as built, no insulation (assumed)	★★☆☆☆	★★☆☆☆
Roof	(another dwelling above)	—	—
Floor	Suspended, no insulation (assumed)	—	—
Windows	Fully double glazed	★★☆☆☆	★★☆☆☆
Main heating	Boiler and radiators, mains gas	★★★★☆	★★★★☆
Main heating controls	Programmer, room thermostat and TRVs	★★★★☆	★★★★☆
Secondary heating	Room heaters, mains gas	—	—
Hot water	From main system	★★★★☆	★★★★☆
Lighting	Good lighting efficiency	★★★★☆	★★★★☆

The energy efficiency rating of your home

Your Energy Efficiency Rating is calculated using the standard UK methodology, RdSAP. This calculates energy used for heating, hot water, lighting and ventilation and then applies fuel costs to that energy use to give an overall rating for your home. The rating is given on a scale of 1 to 100. Other than the cost of fuel for electrical appliances and for cooking, a building with a rating of 100 would cost almost nothing to run.

As we all use our homes in different ways, the energy rating is calculated using standard occupancy assumptions which may be different from the way you use it. The rating also uses national weather information to allow comparison between buildings in different parts of Scotland. However, to make information more relevant to your home, local weather data is used to calculate your energy use, CO_2 emissions, running costs and the savings possible from making improvements.

The impact of your home on the environment

One of the biggest contributors to global warming is carbon dioxide. The energy we use for heating, lighting and power in our homes produces over a quarter of the UK's carbon dioxide emissions. Different fuels produce different amounts of carbon dioxide for every kilowatt hour (kWh) of energy used. The Environmental Impact Rating of your home is calculated by applying these 'carbon factors' for the fuels you use to your overall energy use.

The calculated emissions for your home are 49 kg $CO_2/m^2/yr$.

The average Scottish household produces about 6 tonnes of carbon dioxide every year. Based on this assessment, heating and lighting this home currently produces approximately 3.8 tonnes of carbon dioxide every year. Adopting recommendations in this report can reduce emissions and protect the environment. If you were to install all of these recommendations this could reduce emissions by 1.3 tonnes per year. You could reduce emissions even more by switching to renewable energy sources.

Estimated energy costs for this home

	Current energy costs	Potential energy costs	Potential future savings
Heating	£3,285 over 3 years	£2,088 over 3 years	You could save £1,194 over 3 years
Hot water	£606 over 3 years	£609 over 3 years	
Lighting	£153 over 3 years	£153 over 3 years	
Totals	**£4,044**	**£2,850**	

These figures show how much the average household would spend in this property for heating, lighting and hot water. This excludes energy use for running appliances such as TVs, computers and cookers, and the benefits of any electricity generated by this home (for example, from photovoltaic panels). The potential savings in energy costs show the effect of undertaking all of the recommended measures listed below.

Recommendations for improvement

The measures below will improve the energy and environmental performance of this dwelling. The performance ratings after improvements listed below are cumulative; that is, they assume the improvements have been installed in the order that they appear in the table. Further information about the recommended measures and other simple actions to take today to save money is available from the Home Energy Scotland hotline which can be contacted on 0808 808 2282. Before carrying out work, make sure that the appropriate permissions are obtained, where necessary. This may include permission from a landlord (if you are a tenant) or the need to get a Building Warrant for certain types of work.

	Recommended measures	Indicative cost	Typical saving per year	Rating after improvement	
				Energy	Environment
1	Internal wall insulation	£7,500 - £11,000	£276	C 71	C 70
2	Floor insulation (suspended floor)	£5,000 - £10,000	£121	C 74	C 74

Choosing the right improvement package

For free and impartial advice on choosing suitable measures for your property, contact the Home Energy Scotland hotline on 0808 808 2282 or go to www.greenerscotland.org.

energy saving trust

About the recommended measures to improve your home's performance rating

This section offers additional information and advice on the recommended improvement measures for your home

1 Internal wall insulation

Internal wall insulation involves adding a layer of insulation to the inside surface of the external walls, which reduces heat loss and lowers fuel bills. As it is more expensive than cavity wall insulation it is only recommended for walls without a cavity, or where for technical reasons a cavity cannot be filled. Internal insulation, known as dry-lining, is where a layer of insulation is fixed to the inside surface of external walls; this type of insulation is best applied when rooms require redecorating. Further information can be obtained from the National Insulation Association (www.nationalinsulationassociation.org.uk).

2 Floor insulation (suspended floor)

Insulation of a floor will significantly reduce heat loss; this will improve levels of comfort, reduce energy use and lower fuel bills. Suspended floors can often be insulated from below but must have adequate ventilation to prevent dampness; seek advice about this if unsure. Further information about floor insulation is available from many sources including www.energysavingtrust.org.uk/scotland/Insulation/Floor-insulation. Building regulations generally apply to this work so it is best to check with your local authority building standards department.

Low and zero carbon energy sources

Low and zero carbon (LZC) energy sources are sources of energy that release either very little or no carbon dioxide into the atmosphere when they are used. Installing these sources may help reduce energy bills as well as cutting carbon.

LZC energy sources present: There are none provided for this home

Your home's heat demand

In this section, you can see how much energy you might need to heat your home and provide hot water. These are estimates showing how an average household uses energy. These estimates may not reflect your actual energy use, which could be higher or lower. You might spend more money on heating and hot water if your house is less energy efficient. The table below shows the potential benefit of having your loft and walls insulated. Visit https://energysavingtrust.org.uk/energy-at-home for more information.

Heat demand	Existing dwelling	Impact of loft insulation	Impact of cavity wall insulation	Impact of solid wall insulation
Space heating (kWh per year)	12,055.57	N/A	N/A	N/A
Water heating (kWh per year)	2,551.27			

Addendum

This dwelling has stone walls and so requires further investigation to establish whether these walls are of cavity construction and to determine which type of wall insulation is best suited.

About this document

This Recommendations Report and the accompanying Energy Performance Certificate are valid for a maximum of ten years. These documents cease to be valid where superseded by a more recent assessment of the same building carried out by a member of an Approved Organisation.

The Energy Performance Certificate and this Recommendations Report for this building were produced following an energy assessment undertaken by an assessor accredited by Elmhurst (www.elmhurstenergy.co.uk), an Approved Organisation Appointed by Scottish Ministers. The certificate has been produced under the Energy Performance of Buildings (Scotland) Regulations 2008 from data lodged to the Scottish EPC register. You can verify the validity of this document by visiting www.scottishepcregister.org.uk and entering the report reference number (RRN) printed at the top of this page.

Assessor's name:	Mr. Fergus Mair
Assessor membership number:	EES/009437
Company name/trading name:	DHKK Limited
Address:	54 Corstorphine Road Edinburgh EH12 6JQ
Phone number:	0131 313 0444
Email address:	survey@dhkk.co.uk
Related party disclosure:	No related party

If you have any concerns regarding the content of this report or the service provided by your assessor you should in the first instance raise these matters with your assessor and with the Approved Organisation to which they belong. All Approved Organisations are required to publish their complaints and disciplinary procedures and details can be found online at the web address given above.

Use of this energy performance information

Once lodged by your EPC assessor, this Energy Performance Certificate and Recommendations Report are available to view online at www.scottishepcregister.org.uk, with the facility to search for any single record by entering the property address. This gives everyone access to any current, valid EPC except where a property has a Green Deal Plan, in which case the report reference number (RRN) must first be provided. The energy performance data in these documents, together with other building information gathered during the assessment is held on the Scottish EPC Register and is available to authorised recipients, including organisations delivering energy efficiency and carbon reduction initiatives on behalf of the Scottish and UK governments. A range of data from all assessments undertaken in Scotland is also published periodically by the Scottish Government. Further information on these matters and on Energy Performance Certificates in general, can be found at www.gov.scot/epc.

Advice and support to improve this property

There is support available, which could help you carry out some of the improvements recommended for this property on page 3 and stop wasting energy and money.For more information, visit greenerscotland.org or contact Home Energy Scotland on 0808 808 2282.

Home Energy Scotland's independent and expert advisors can offer free and impartial advice on all aspects of energy efficiency, renewable energy and more.

HOMEENERGYSCOTLAND.ORG
0808 808 2282
FUNDED BY THE SCOTTISH GOVERNMENT

Greener Scotland
Scottish Government

DHKK

CHARTERED SURVEYORS

PROPERTY QUESTIONNAIRE



PROPERTY QUESTIONNAIRE

Note for sellers

- Please complete this form carefully. It is important that your answers are correct.
- The information in your answers will help ensure that the sale of your house goes smoothly. Please answer each question with as much detailed information as you can.
- If anything changes after you fill in this questionnaire but before the date of entry for the sale of your house, tell your solicitor or estate agent immediately.

Information to be given to prospective buyer(s)

1.	**Length of ownership**	
	How long have you owned the property? Property of my deceased mother who owned the property for over 20 years.	
2.	**Council tax**	
	Which Council Tax band is your property in? (Please tick one) ☐A ☐B ☐C ☐D ☒E ☐F ☐G ☐H	
3.	**Parking**	
	What are the arrangements for parking at your property? (Please tick all that apply) • Garage ☐ • Allocated parking space ☐ • Driveway ☐ • Shared parking ☐ • On street ☐ • Resident permit ☒ • Metered parking ☐ • Other (please specify):	
4.	**Conservation area**	
	Is your property in a designated Conservation Area (that is an area of special architectural or historical interest, the character or appearance of which it is desirable to preserve or enhance)?	☒ Yes ☐ No ☐ Don't know
5.	**Listed buildings**	
	Is your property a Listed Building, or contained within one (that is a building recognised and approved as being of special architectural or historical interest)?	☐ Yes ☒ No

PROPERTY QUESTIONNAIRE

6.	**Alterations/additions/extensions**	
a.	(i) During your time in the property, have you carried out any structural alterations, additions or extensions (for example, provision of an extra bath/shower room, toilet, or bedroom)? If you have answered yes, please describe below the changes which you have made: No structural alterations. However, the property was previously connected to the next door flat (no.30) by a communicating door. This has now been blocked off. No other alterations. (Building Warrant obtained and with solicitor)	☐ Yes ☒ No
	(ii) Did you obtain planning permission, building warrant, completion certificate and other consents for this work? If you have answered yes, the relevant documents will be needed by the purchaser and you should give them to your solicitor as soon as possible for checking. If you do not have the documents yourself, please note below who has these documents and your solicitor or estate agent will arrange to obtain them:	☐ Yes ☒ No
b.	Have you had replacement windows, doors, patio doors or double glazing installed in your property? If you have answered yes, please answer the three questions below:	☐ Yes ☒ No
	(i) Were the replacements the same shape and type as the ones you replaced?	☐ Yes ☐ No
	(ii) Did this work involve any changes to the window or door openings?	☐ Yes ☐ No
	(iii) Please describe the changes made to the windows doors, or patio doors (with approximate dates when the work was completed): Please give any guarantees which you received for this work to your solicitor or estate agent.	

PROPERTY QUESTIONNAIRE

7.	**Central heating**	
a.	Is there a central heating system in your property? (Note: a partial central heating system is one which does not heat all the main rooms of the property - the main living room, the bedroom(s), the hall and the bathroom). <u>If you have answered yes or partial</u> – what kind of central heating is there? (Examples: gas fired, solid fuel, electric storage heating, gas warm air). Gas fired <u>If you have answered yes</u>, please answer the three questions below:	☒ Yes ☐ No ☐ Partial
	(i) When was your central heating system or partial central heating system installed? Boiler installed < 10 years ago	
	(ii) Do you have a maintenance contract for the central heating system? <u>If you have answered yes</u>, please give details of the company with which you have a maintenance contract:	☐ Yes ☒ No
	(iii) When was your maintenance agreement last renewed? (Please provide the month and year).	
8.	**Energy Performance Certificate**	
	Does your property have an Energy Performance Certificate which is less than 10 years old?	☒ Yes ☐ No
9.	**Issues that may have affected your property**	
a.	Has there been any storm, flood, fire or other structural damage to your property while you have owned it? <u>If you have answered yes</u>, is the damage the subject of any outstanding insurance claim?	☐ Yes ☒ No ☐ Yes ☐ No
b.	Are you aware of the existence of asbestos in your property? <u>If you have answered yes</u>, please give details:	☐ Yes ☒ No

PROPERTY QUESTIONNAIRE

10. Services

a. Please tick which services are connected to your property and give details of the supplier:

Services	Connected	Supplier
Gas or liquid petroleum gas	**Yes**	**Good Energy**
Water mains or private water supply	**Mains**	**Scottish Water**
Electricity	**Yes**	**Good Energy**
Mains drainage	**Yes**	**Scottish Water**
Telephone	**No - disconnected**	
Cable TV or satellite	**No**	
Broadband	**No**	

b.	Is there a septic tank system at your property? If you have answered yes, please answer the two questions below:	☐ Yes ☒ No
	(iv) Do you have appropriate consents for the discharge from your septic tank?	☐ Yes ☐ No ☐ Don't Know
	(v) Do you have a maintenance contract for your septic tank? If you have answered yes, please give details of the company with which you have a maintenance contract:	☐ Yes ☐ No
11.	**Responsibilities for shared or common areas**	
a.	Are you aware of any responsibility to contribute to the cost of anything used jointly, such as the repair of a shared drive, private road, boundary, or garden area? If you have answered yes, please give details:	☐ Yes ☒ No ☐ Don't Know

b.	Is there a responsibility to contribute to repair and maintenance of the roof, common stairwell or other common areas? If you have answered yes, please give details: Roof and gable walls	☒ Yes ☐ No ☐ Not Applicable
c.	Has there been any major repair or replacement of any part of the roof during the time you have owned the property?	☐ Yes ☒ No
d.	Do you have the right to walk over any of your neighbours' property - for example to put out your rubbish bin or to maintain your boundaries? If you have answered yes, please give details:	☐ Yes ☒ No
e.	As far as you are aware, do any of your neighbours have the right to walk over your property, for example to put out their rubbish bin or to maintain their boundaries? If you have answered yes, please give details:	☐ Yes ☒ No
f.	As far as you are aware, is there a public right of way across any part of your property? (public right of way is a way over which the public has a right to pass, whether or not the land is privately owned). If you have answered yes, please give details:	☐ Yes ☒ No
12.	**Charges associated with your property**	
a.	Is there a factor or property manager for your property? If you have answered yes, please provide the name and address, and give details of any deposit held and approximate charges:	☐ Yes ☒ No
b.	Is there a common buildings insurance policy? If you have answered yes, is the cost of the insurance included in your monthly/annual factor's charges?	☐ Yes ☒ No ☐ Don't Know ☐ Yes ☐ No ☐ Don't Know
c.	Please give details of any other charges you have to pay on a regular basis for the upkeep of common areas or repair works, for example to a residents' association, or maintenance or stair fund.	

PROPERTY QUESTIONNAIRE

13.	**Specialist works**	
a.	As far as you are aware, has treatment of dry rot, wet rot, damp or any other specialist work ever been carried out to your property? If you have answered yes, please say what the repairs were for, whether you carried out the repairs (and when) or if they were done before you bought the property.	☐ Yes ☒ No
b.	As far as you are aware, has any preventative work for dry rot, wet rot, or damp ever been carried out to your property? If you have answered yes, please give details:	☐ Yes ☒ No
c.	If you have answered yes to 13 (a) or (b), do you have any guarantees relating to this work? If you have answered yes, these guarantees will be needed by the purchaser and should be given to your solicitor as soon as possible for checking. If you do not have them yourself please write below who has these documents and your solicitor or estate agent will arrange for them to be obtained. You will also need to provide a description of the work carried out. This may be shown in the original estimate. Guarantees are held by:	☐ Yes ☐ No

14.	**Guarantees**					
a.	Are there any guarantees or warranties for any of the following:					
		No	Yes	Don't know	With title deeds	Lost
(i)	Electrical work	☒	☐	☐	☐	☐
(ii)	Roofing	☒	☐	☐	☐	☐
(iii)	Central heating	☒	☐	☐	☐	☐
(iv)	National House Building Council (NHBC)	☒	☐	☐	☐	☐
(v)	Damp course	☒	☐	☐	☐	☐
(vi)	Any other work or installations? (for example, cavity wall insulation, underpinning, indemnity policy)	☒	☐	☐	☐	☐
b.	If you have answered 'yes' or 'with title deeds', please give details of the work or installations to which the guarantee(s) relate(s):					

PROPERTY QUESTIONNAIRE

c.	Are there any outstanding claims under any of the guarantees listed above? If you have answered yes, please give details:	☐ Yes ☒ No
15.	**Boundaries**	
	So far as you are aware, has any boundary of your property been moved in the last 10 years? If you have answered yes, please give details:	☐ Yes ☒ No ☐ Don't know
16.	**Notices that affect your property**	
	In the past three years have you ever received a notice:	
a.	advising that the owner of a neighbouring property has made a planning application?	☐ Yes ☒ No
b.	that affects your property in some other way?	☐ Yes ☒ No
c.	that requires you to do any maintenance, repairs or improvements to your property?	☐ Yes ☒ No
	If you have answered yes to any of a–c above, please give the notices to your solicitor or estate agent, including any notices which arrive at any time before the date of entry of the purchaser of your property.	

Date Completed – 06/10/2026

DHKK

CHARTERED SURVEYORS

Home Reports

Scheme 1 and Mortgage Valuation Reports

Scheme 2 and Homebuyer Reports

Tax Valuation

Pre-sale Advice

Schedules of Condition and Condition Reports

Energy Performance Certificate (EPC)

Commercial EPCs

Section 63s

Display Energy Performance Certificate (DECs)

Expert Witness

VALENTINE PROPERTY SERVICES LTD.

SPECIALISTS IN WOODWORM, DRY ROT AND DAMPNESS CONTROL AND GENERAL BUILDING SERVICES

Registered Office:
37 TOWER STREET
EDINBURGH EH6 7BN

Telephone: 0131 - 553 7858
Fax: 0131 - 554 4674

Our Ref: SL/SW/2/13956

20th October 2026

Urquharts Edinburgh
16 Heriot Row
Edinburgh
EH3 6HR

For the attention of Ms H Sheran

Dear Madam

RE: 31 HOLLYBANK TERRACE EDINBURGH

Thank you for your instructions to carry out a Damp survey of the above property and following our inspection on Monday 19th October 2026 confirmation of our findings together with recommendations are as follows.

DAMP READINGS

Using our moisture meter we tested the lower section of the accessible walls throughout the property where we recorded elevated readings, in excess of tolerable levels, affecting the following specified walls.

Entrance Vestibule - all walls
Front Left Bedroom – front elevation (either side of Bay window)
Front Facing Sitting room – front elevation (either side of Bay window)

We believe that the high readings are being caused due to Rising Damp, salt contamination of plasterwork or a combination of both and we therefore recommend the insertion of our guaranteed pressure injection Damp Proof Course to the specified walls and this will be carried out as detailed on the attached schedule of works headed "Damp Proofing Works".

An integral part of the Damp Proof treatment is in the reinstatement of plaster, which must be Tilcon Limelite renovating plaster applied to the walls where plastered directly onto the hard. We have therefore allowed for this section of work in the attached quotation. Please note that should the plasterwork exceed a thickness of 20mm we may use the option of installing a membrane and finishing with a Gypsum board.

If the treatment for Rising Damp is carried out in accordance with our specification, we are prepared to issue our 30 Year Guarantee covering the treatment areas as soon as the account is settled in full.

Our quotation for carrying out the remedial repairs and treatments as recommended and detailed on the attached Schedule of Work is attached and on receipt of your acceptance arrangements will be made to commence the work as soon as possible.

Please note that our quotation does not include for any redecoration works as any redecoration works should be carried out by your own Contractor, working at a direct cost to yourselves.

The areas detailed above are the extent of the dampness at the time of our inspection. Should we find that on opening up that further works are required then an additional quotation will be sent for your approval.

Please note that regarding the survey of the building, this is a non-invasive survey and therefore areas which are inaccessible we cannot comment on and therefore are not liable for any issues regarding sections which were inaccessible during our visit. These include lack of access to sub-floor areas, beneath floor coverings i.e. carpets and vinyl, behind dry lining, behind any wall paneling or bath paneling, behind kitchen units and behind tiling. Our survey consists of testing using an electronic moisture meter device to all accessible surfaces and also a visual inspection.

A normal supply of electricity and water must be available at all times on site for Our Technician's use.

Please note that we realise that the bulk of our work is fairly disruptive, but we shall endeavour to keep the disruption and inconvenience to a minimum. However, in order to reduce any inconvenience, we would recommend the removal of all furniture, soft furnishing, carpets etc from the immediate working areas prior to the works commencing. We shall not be held responsible for any loss or damage to items of furniture or personal belongings remaining in the immediate working areas.

Please note that should these works be subject to an insurance claim, we stress that our contract is with you and not the Insurance Company. Whilst we will assist you in your claim, under no circumstances are we prepared to wait until the Insurance Company settles your claim. In all cases our account should be settled within fourteen days as stipulated in our Terms and Conditions.

We enclose our invoice in relation to this inspection.

We trust that this is satisfactory however should you have any further queries then please do not hesitate to contact our Mr Laing.

Yours faithfully

STUART LAING
For Valentine Property Services Limited

VALENTINE PROPERTY SERVICES LTD.

SCHEDULE AND SPECIFICATION OF WORKS

THIS SCHEDULE REFERS TO:- **DAMP PROOFING WORKS** DATE: **20th OCTOBER 2026**

PROPERTY: **31 HOLLYBANK TERRACE EDINBURGH**

Location	Client's Contractor (under separate contract)	-1-	Our Technicians

SPECIFIED WALLS
Entrance Vestibule - all walls
Front Left Bedroom – front elevation (either side of Bay window)
Front Facing Sitting room – front elevation (either side of Bay window)

Carefully remove the timber skirting boards along the specified walls and set aside for later refitting, if in a sound condition and free from decay. Please note that should the skirtings be decayed and need to be replaced then a further quotation will be submitted to you for your approval prior to the fitting of new skirtings.
Carefully strip the salt contaminated and damp affected wall plaster for 1m up from floor level to the specified walls.
Lathe and plasterboard walls to be stripped up 100mm from floor level.
On completion of preparatory works carry out preparatory drilling and carry out Damp Course Injections to the specified walls to comply with our Rising Damp Specification.
Please note that should the plasterwork exceed a thickness of 20mm we may use the option of installing a membrane and finishing with a Gypsum board.
Supply and fix in position pre-treated grounds.
Allow for re-plastering using Limelite renovating undercoat and finish with a skim coat of plaster.
Refit previously removed skirting boards having been pre-treated on the unpainted surfaces.
Bag up debris and remove from site for safe disposal.

For Specification of Standard Treatments and Health and Safety Measures see over.

SPECIFICATION OF TIMBER DECAY AND RISING DAMP TREATMENTS

REPLACEMENT TIMBER SPECIFICATION (WET ROT/DRY ROT)

Cut back flooring, cut out and remove affected timbers as detailed. Build in as required new treated timbers. Further protect all bearing surfaces by wrapping in damp proof course material or coating with a bituminous solution. Where felt necessary any loadbearing timbers may be re-instated using concrete or steel sections. Galvanised steel hangers can be used to support joist ends where recommended.

WALL IRRIGATION SPECIFICATION (DRY ROT ONLY)

Wire brush exposed wall areas to remove surface mycelium. Drill prepared walls of 9 inch (225mm) thickness or over (on both sides of internal walls over 13½ inches (338mm) thick) at staggered intervals, the holes being inclined downwards and extended to just over half the wall thickness. Cut pockets where necessary at the specified limit of growth for inspection purposes. Irrigate prepared walls through drill holes and by surface spray with fungicidal fluid. Saturate, if specified, the exposed solumn area.

All sound retained timbers within 3 feet (1m) of the attack and all replacements will be treated with fungicidal fluid.

RISING DAMP SPECIFICATION

The damp proof course treatment consists of drilling horizontally into the brickwork/stonework at selected centres and injecting the fluid from a pressure pump through injectors inserted into the drill holes. The pump pressure is built up to approximately 7kg/cm^2 (100lbs/in^2) until saturation is indicated. As water has been rising in the walls for some time the plaster will contain hygroscopic salts which attract moisture from the atmosphere, and for this reason, before inserting the D.P.C. it is necessary to strip plaster to the specified height. It will also be necessary to remove skirtings, grounds, etc., from specified walls, and where decayed these will require renewal.

Replastering. It must be understood that after insertion of a D.P.C. the water already in the wall has to evaporate before normally dry conditions can be obtained. The length of time involved must, of course, be governed by the initial moisture content and wall thickness. It should be noted that a drying time of one month per inch thickness, is often experienced on a very damp wall and the first decoration after treatment must therefore be regarded as temporary. Only a porous paper should be hung and any paint applied to same should be water based. Replastering can commence almost immediately after insertion of a damp proof course, but to prevent residual salts in walls migrating to the surface and spoiling decoration, replastering must be carried out in accordance with our specification detailed below. Local conditions, wall materials and type of construction would determine any variations to our standard specification or remedial treatments, any such variations will be decided only by this Company.

INTERNAL WALL REPLASTERING SPECIFICATION

Limelight Renovating Plaster used to manufacturer's specification or an alternative plaster rendering approved by this Company. UNDER NO CIRCUMSTANCES SHOULD ANY OTHER PRE-MIX PLASTERS BE USED.

EXTERNAL WALL REPLASTERING SPECIFICATION

Supply and fit gyproc plaster plate to joiner's strappings, being finished with two coats of hardwall plaster.

Bottom edge of plaster both on hard and on gyproc must not bridge new damp proof course or come in contact with a solid floor.

HEALTH AND SAFETY
SAFETY MEASURES

All timber preservatives and damp proofing products employed by this Company are approved by the Health & Safety Executive and once installed should present no hazard to the environment. In confined areas, arrange good ventilation. DO NOT SMOKE. After treatment, maintain ventilation. ALL UNPROTECTED PERSONS INCLUDING CHILDREN AND PETS SHOULD BE KEPT AWAY FROM TREATED AREAS FOR 48 HOURS.

VALENTINE PROPERTY SERVICES LTD.

SPECIALISTS IN WOODWORM, DRY ROT AND DAMPNESS CONTROL AND GENERAL BUILDING SERVICES

37 TOWER STREET
EDINBURGH EH6 7BN

Telephone: 0131 - 553 7858
Fax: 0131 - 554 4674

Our Ref: SL/SW/2/13956

20th October 2026

Urquharts Edinburgh
16 Heriot Row
Edinburgh
EH3 6HR

QUOTATION

For the attention of Ms H Sheran

RE: 31 HOLLYBANK TERRACE EDINBURGH

For carrying out guaranteed insertion of Damp Proof Course to the specified walls as specified in our report dated 20th October 2026…

£1,920 (Plus VAT at standard rate)
One thousand, nine hundred and twenty pounds

STUART LAING
For Valentine Property Services Limited

Subject to the terms and conditions overleaf we will carry out remedial work and chemical treatment as above and as detailed in our attached Report and Schedule under the heading "Our Operatives".

To accept this Quotation please sign and return the attached Acceptance of Estimate Form.

TERMS AND CONDITIONS

1. This quotation shall only be binding upon the Company if accepted in writing within a period of 28 days from the date of issue.
2. The quotation exclusive of Value Added Tax which will be charged where applicable, at the appropriate rate.
3. The quotation is based on the report number quoted and refers only to the work detailed in such area as recommended in that report.
4. The Company shall be entitled at its discretion to alter or vary the specified materials or method of carrying out the work in whole or in part without increase in price to the client in the event of any such alteration or variation resulting in a substantial reduction in the cost of the work the Company will at its discretion make such allowance, if any, to the client as the company shall consider fair and reasonable.
5. Whilst the Company shall make every endeavour to start and complete the work by the dates indicated, it shall not be held responsible for any delays.
6. Payment is due nett on completion of the work, or if the work is done in stages, payment for any stage is due on completion of that stage of the work.
7. During the course of the contract the Company reserves the right to demand interim payments for work done. Failure to pay within seven days will result in withdrawal of labour until payment is received.
8. Except where occasioned by the negligence of the Company or its servants, the Company accepts no liability for loss, damage or injury, whether arising during or as a result of the work to the premises to be treated or any adjoining premises, or to any persons, or to any animal or plant life therein, or for any nuisance caused to the Owners or Occupiers of any such premises, and the client shall release and indemnify the Company from and against all claims by any person arising from such loss, damage or injury to the client for and the client will indemnify the Company against claims by any person for:-
   (i) Damage to interior decoration and paint. Whilst the Company shall use its best endeavours to avoid any such damage there is always the risk of discolouration of ceilings, and particularly polystyrene tiles fixed to ceilings etc., arising through the treatment of ceiling joists. Redecoration should not be attempted until the preservation has dried thoroughly.
   (ii) Collapse of insecure brickwork, stonework, cementwork, plasterwork, woodwork, etc., during or as the result of the Company's work. If after commencement of work unforseen difficulties arise due to the collapse of insecure work or to irregular bonding thereof or any other cause the additional unforeseen work found to be necessary will be charged extra.
   (iii) Damage arising as a result of the client's having:
      (a) failed to remove from the premises any liquids or foodstuffs liable to contamination during the course of treatment.
      (b) replaced carpets or floor coverings before the solvent has evaporated.
      (c) layed *'vinyl'* floor coverings on floors that have been treated, the client is advised not to lay such coverings without first obtaining the floor covering manufacturer's recommendations.
9. When chemical treatment is being carried out in any building which involves the use of any organic solvent material the electrical supply to the area being treated shall be switched off by the client in the interest of safety during treatment and for 48 hours after the conclusion thereof. Naked flames should not be permitted for the same period. However the client is required to provide a main electricity supply, free of charge, for lighting and power purposes.
10. On completion of the work and on payment of our account the Company shall issue a guarantee against re-infestation by the insects or fungi or the recurrence of rising damp as detailed in the areas treated in the Company's usual form a copy of which will be supplied on request. This guarantee is issued subject to the property being kept in a wind and water-tight condition with all water supply and waste disposal fittings being maintained in good condition.
11. The balance of our invoice to be paid in full within 14 days from date of invoice. If payment in full is not made the outstanding balance will be charged interest at 3% above bank base rate.

VALENTINE PROPERTY SERVICES LTD.

SPECIALISTS IN WOODWORM, DRY ROT AND DAMPNESS CONTROL AND GENERAL BUILDING SERVICES

37 TOWER STREET
EDINBURGH EH6 7BN

Telephone: 0131 - 553 7858
Fax: 0131 - 554 4674

Our Ref: SL/SW/2/13956

20th October 2026

Urquharts Edinburgh
16 Heriot Row
Edinburgh
EH3 6HR

ACCEPTANCE OF QUOTATION

For the attention of Ms H Sheran

RE: 31 HOLLYBANK TERRACE EDINBURGH

For carrying out guaranteed insertion of Damp Proof Course to the specified walls as specified in our report dated 20th October 2026...

£1,920 (Plus VAT at standard rate)
One thousand, nine hundred and twenty pounds

Dear Sirs

I/we accept your Quotation in accordance with the terms and conditions

I/we should like the work to commence on _____

Signed _____ Dated _____